

CV AUDIO TESTING

PAT TEST

23.02.22

ANDREW SHARPE/STEAMCHICKEN/THE CELLAR TAPES

The following equipment was tested today and found to comply with electrical standards under the Health and Safety "Electricity at Work Regulations" 1989 No. 635.

Tests carried out:

1. Visual test of plugs, leads and fuses.
2. Earth continuity test - resistance of earth between earth pin and earth points on appliance less than 0.1 ohms
3. Insulation resistance test - resistance between current conductors and earth more than 2 Megohms.

PLEASE NOTE: The above apply to all Class I appliances. Class II appliances are double insulated and do not normally have an earth connector. Class III appliances are low voltage devices supplied by isolating transformers and are not normally earthed.

Class	Make	Model No	Serial No	Description	Pass
II	Roland	RD170	ZQ90775	Keyboard	PassFeb22
I	Laney	CP10	KFB3046	Pow/monitor	PassFeb22
I	Yamaha	PAS300	Not visible	Amp module	PassFeb22
III	Roland	Micro Cube	B3B8982	Combo amp	PassFeb22
I	13amp/IEC	Kettle leads			PassFeb22
I	13amp/13amp	Ass'd mains leads			PassFeb22

TESTED AS ABOVE

22.02.22

Graham Bradshaw
CV Audio